



CHHATTISGARH STATE POWER TRANSMISSION COMPANY LIMITED

छत्तीसगढ़ स्टेट पावर ट्रांसमिशन कंपनी लिमिटेड

(C.G. Govt. Undertaking) (छत्तीसगढ़ शासन का एक उपक्रम)

CIN-U40108CT2003SGC015820

CHHATTISGARH STATE LOAD DESPATCH CENTRE: RAIPUR

GST No. - 22AADCC5773E1ZX

छत्तीसगढ़ राज्य भार प्रेषण केन्द्र, रायपुर

दूरभाष PHONE: 0771-2574172,

फैक्स FAX NO. 0771-2574174.

Web Site: www.sldccg.com

email: csebsldc@sldccg.com

Ref: 03-02/ED/LD/TR-141/ 1246

Raipur, Dated:19/11/2020

// Corrigendum //

In continuation to the earlier issued NIT vide no. No. 03-02/ED/SLDC/ TR-141/2020/1135, Raipur, Dated 29/10/2020 which was published in newspaper for Implementation of Automatic Demand Management System (ADMS) in Chhattisgarh State having below mentioned amendments:-

1. CLAUSE 1.4 Part-I (Earnest Money Deposit): - As per Section 1.5 of the tender, CLAUSE (Page No. - 15 of the Tender document) 3.4.1 ENVELOPE-I: Earnest Money Deposit: Please refer Section - 1.5 (Page No. - 40 of the Tender document) And CLAUSE 3.10.1(i) ENVELOPE - I:- (To contain the EMD) "This envelope should contain a covering letter with Earnest Money (EMD) or earnest money exemption certificate. The cover of the envelope should be suitably super-scribed with the details of earnest money and tender **number**. The envelope should be sealed properly" (Page No. - 46) **SHALL READ AS** CLAUSE 1.4 Part-I (Earnest Money Deposit **& TENDER FEE**): - As per Section 1.5 of the tender, CLAUSE (Page No. - 15) 3.4.1 ENVELOPE-I: Earnest Money Deposit **& TENDER FEE**: Please refer Section - 1.5 (Page No. -40) And CLAUSE 3.10.1(i) ENVELOPE - I:- (To contain the EMD **& TENDER FEE**) "This envelope should contain a covering letter with Earnest Money (EMD) or earnest money exemption certificate. The cover of the envelope should be suitably super-scribed with the details of **EARNEST MONEY** and **TENDER FEE**. The envelope should be sealed properly" (Page No. - 46).
2. PRE-BID QUALIFYING REQUIREMENTS: Qualification Criteria (Page No. 12 of the Tender document) "D.The Bidders should have "ISO/IEC - 27001:2018, ISO/IEC - 20000-1:2018, ISO - 9001: 2015 / latest and have at least CMMI ML 3 or above" certification requirement **shall read as** "**ISO/IEC - 27001:2013**, ISO/IEC - 20000-1:2018, ISO - 9001: 2015 / latest and have at least CMMI ML 3 or above".
3. SECTION-I: INSTRUCTIONS FOR BIDDERS /JV PARTNERS/TENDERERS Clause 1.6.2 (Page No. 18 of tender document) Signed Tender Document, Affidavits,

Undertaking & Pre Contract Integrity Pact etc. : Bidder/ JV Partners should ensure that in addition to the PQR following documents are adequately signed by authorized signatory and placed in the **Second Envelope** of their offer.

At sub clause (v) of 1.6.2 "Duly filled Questionnaire as per **Schedule – II A & Schedule-III** along with documentary evidences mentioned therein, as per status of the tenderer"

Sub Clause (v) of 1.6.2 **shall be read as** "Duly filled Questionnaire as per **Schedule - V** along with documentary evidences mentioned therein, as per status of the tenderer" in conjunction with clause sub clause (vii) of 1.6.2.

4. The tender sub clause (ix) of 1.6.2(Page No. 18 of tender document) "Copies of Profit & Loss account/Balance sheet for last **Three year**" shall read as "**Copies of Profit & Loss account/Balance sheet for last Six years**" in conjunction with section B(a) **Financial Criteria of PQR**(Page No. 11 of tender document).
5. Tender Sub clause 1.7.1 Techno-Commercial Bid (Page No. 19 of tender document): "The Bidder/JV Partners is to submit the filled in the Technical and commercial questionnaire as per the **Schedule –II A & Schedule-III** of the tender. And shall be placed in the Envelope–III" **shall read as** "The Bidder/JV Partners is to submit the filled in the Technical and commercial questionnaire as per the **Schedule –II** & Schedule-III of the tender. And shall be placed in the Envelope–III"
6. The tender cause Clause No. 2.11 (Page 29 of Tender document) shall be considered in conjunction with Clause No. 4.8 (Page 69 of the Tender document). Penalty is applicable only after consideration of response & resolution time defined under clause 4.8 of tender document.
7. SECTION-II: GENERAL TERMS AND CONDITIONS OF CONTRACT Clause 2.22 & Clause 3.4.4.4.2 tabulated at Sr. No. (v) (Page No.33 & 42 of Tender Document) "**Payment against Documentation Handovers**" = "**05%**" **shall be read as 01%** "**Payment against Documentation Handovers**" = "**15%**".
8. The tender clause 3.4.4.2 is omitted.
9. SECTION-IV: TECHNICAL SPECIFICATION FOR ADMS Clause 4.5.2 (Page No. 57 of Tender document) FOR PART- A - I EQUIPMENTS : Industrial Grade Servers: Item No. 6 -Dual VGA port and two 40" LED monitor including 20 feet VGA cable with VGA extender which can run up to 100 mtr **shall read as** "Industrial Grade Servers: Item No. 6 –Dual HDMI port and two 40" LED monitor **per server (Total 12 Monitor) including 6 No's 20 feet HDMI cable with 6 No's HDMI extender which can run up to 100 mtr**".

10. SECTION-IV: TECHNICAL SPECIFICATION FOR ADMS Clause 4.5.2.6 (Page No.

60) Tripping contactor specification **shall read as**

1. Total Quantity as per BoM

2. Specification to be read as:

a: Insulation Resistance: 500 M Ohms at 500V DC , 25 Deg C, 50 RH

b. Rated Coil Voltage: 24-110/220V DC

c: This specification is omitted

d: No. operation cycles - 10 million;

e. Rated current minimum - 10A for 110/220V DC operation

11. SECTION-IV: TECHNICAL SPECIFICATION FOR ADMS Clause 4.5.2.12 (Page No. 61 of Tender Document) Feeder Tripping relay specification is **deleted**.

12. In the SCHEDULE - II (B) & SCHEDULE -II (C) (Page No. 90 & 91 of Tender documents)

a. In SCHEDULE -II (B) GTP of Desktop Computers **shall be read as** GTP of LMU Server.

b. In SCHEDULE -II (C) 04 Nos. 2 KVA Online UPS with 1 Hr Battery backup to be provided at LMU Locations.

Bidder has to provide the GTP of offered LMU Server and UPS.

13. In the SCHEDULE – IV (C) (Page No 99 of Tender Document): PART-A ITEMS PRICE BID (PART- A ITEMS) required Tabulated Item Code – “ADMS-MAT1, S.No. 1 : Development supply and installation of ADMS Server, Engineering Station, MIS, Control Cubicle with ADMS software, Window base as per Technical specification for all 5 Control centre's = 01 Job” **shall read as** “ Item Code - ADMS- MAT1 - Under S.No. 1 : Development, testing & implementation of ADMS Software as per technical specification requirement = 01 Job”.

And also Item Code – “ADMS- MAT2 - Under S.No. 2: Industrial grade PC having configuration as per technical specifications for all 5 Nos. Control Centre along with required networking equipment and Printer. = 6 Nos. **shall read as** “Item Code - ADMS-MAT2, S.No. 2: Supply of Industrial Grade Servers/PCs = 06 Nos”.

14. In the SCHEDULE – IV (D): PART-A ITEMS- In the tabulated section B Service detail:



- At Sr. No. 11. Installation & testing charges for Panel: 50 Nos.
- At Sr. No. 12. Installation & testing charges for RTU and other items: 50 Nos.
- At Sr. No. 15. Service charges per MFT Installation and Integration: 50 Nos.
- At Sr. No. 16. Installation & fitting charges of Annunciation Panel: 91 Nos.

SHALL BE READ AS BELOW

- At Sr. No. 11. Installation & testing charges for Panel: 45 Nos.
- At Sr. No. 12. Installation & testing charges for RTU and other items: 45 Nos.
- At Sr. No. 15. Service charges per MFT Installation and Integration: 45 Nos.
- At Sr. No. 16. Installation & fitting charges of Annunciation Panel: 45 Nos.

15. In the SECTION-IV: TECHNICAL SPECIFICATION FOR ADMS Clause 4.5.2.1 (Page No. 57 of Tender Documents) , Under Heading of Automatic Demand Management Server (ADMS) - Qty 6 No's Industrial Grade Server **additional Point No. 10. is incorporated where 1 Table and 1 Chair per server shall be provided.**

16. SECTION-V: SCOPE OF WORK Clause 5.13 (Page No. 74 of Tender Documents) TOOLS, TACKLES, & CONSUMABLES left requirement is added and **shall read as "Cable Laying at Control Centers and sub stations should be in HDPE conduit or Armoured Cable"**.


 Executive Director
 SLDC, CSPTCL, Raipur
 o/c  19/11/20

Copy To:

1. The SE O/o MD (Trans), CSPTCL Raipur
2. The ED (S/S-O&M), CSPTCL, Raipur
3. The CE (C&RA), CSPTCL, Raipur
4. The Chief Engineer (EITC) CSPDCL, Raipur. - It is requested to please arrange publication of NIT in the web site of CSPTCL..