



SUMMARY OF STATEMENT OF DSM CHARGES (PROVISIONAL)

No:- 03-02/SLDC /DSM /1332

Date : 23-Sep-2016

To,

The Executive Director (Finance)

CSP Distribution Co. Ltd.,
Dangania, Raipur.

Sub:- Provisional statement of DSM Charges under open access for the period from **05-Sep-2016** to **11-Sep-2016** in respect of OACs .

Please find enclosed herewith the provisional statement of DSM Charges under open access in respect of the open access customers for the period from **05-Sep-2016** to **11-Sep-2016** for information and necessary action.

Billing Ref.No :- SLDC/DSM/2016-W36

Summary of DSM Charges for period from **05-Sep-2016** to **11-Sep-2016**

ENTITY_ID	Total Injected Energy in KWh	Injected Energy towards Interstate & PPA Schedule in KWh	Schedule towards Interstate & PPA in KWh	Deviation Energy on Underinjection in KWh	CFD** for Underinjection in ₹	CFD** for Overinjection in ₹	Addl_CFD** for Underinjection in ₹	Addl_CFD** for Overinjection in ₹	Total Charges* in ₹	Deviation* in %
1. SVPPL CSEB	8,461,765.62	8,461,765.62	8,004,480.00	-70,473	-73,278	942,471	-45,293	0	823,900	5.71
TOTAL	8,461,766	8,461,766	8,004,480	-70,473	-73,278	942,471	-45,293	0	823,900	5.71

* -ve (minus) implies Under Injection/Payable by the OA customer ;+ve(plus) Implies Over injection/receivable by OA customer.

** CFD means Charges for Deviation and Addl_CFD means Additional Charges for Deviation.

Inconsistencies/errors observed if any, should be informed to this office within 5 days from the date of issue of the bill.

Remarks :- The details of the above DSM Charges statement shall be available shortly on the CGSLDC website (www.sldccg.gov.in) under the link **Commercial -> DSM Charges of OAC**

Superintending Engineer (MO)
SLDC, CSPTCL, Raipur

Copy to:-

1. The Executive Director (Commercial), C.S.P. Distribution C.L., Raipur.
2. The Chief Engineer (S/S:O&M), C.S.P.Transmission C.L., Raipur.
3. The Chief Engineer (Tech.Cell), C.S.P.Trading C.L., Raipur.
4. The Superintending Engineer (SO), SLDC, Control-Room, C.S.P.Transmission C.L., Raipur.
5. The Executive Engineer (MRT Dn.), C.S.P.Transmission C.L., Bilaspur.
6. The EE (OA)/ EE (RA)/ Manager (F&A), O/o CE (LD), CSPTCL, Raipur

-For information and necessary action please.



1. Mailing Address:- **STATEMENT OF DSM CHARGES (PROVISIONAL)** Billing Ref. No: **SLDC/DSM/2016-W36**

To,
M/s S V Power Pvt. Ltd. (SVPPL CSEB)
Renki Village, Chainpur Post, Teh- Pali, Hardibazar,
Distt - Korba (CG)
495446 , Fax No -07815-256801

Kind Attn:- Mr.P.K. Sood/Mr. Sanjeev Kumar

2. Date of Issue of DSM Charges Statement: **23-Sep-2016** Due Date of Payment: **03-Oct-2016**

3. Summary on DSM Charges for **SVPPL CSEB** for the period **05-Sep-2016** to **11-Sep-2016**

For Date	Total Injected Energy in KWh	Injected Energy towards Interstate & PPA Schedule in KWh	Schedule towards Interstate & PPA in KWh	Deviation Energy on Underinjection in KWh	CFD** for Underinjection in ₹	Deviation Energy on Overinjection upto 12% of schedule in KWh	CFD** for Overinjection in ₹	Addl_CFD** for Underinjection in ₹	Addl_CFD** for Overinjection in ₹	Total Charges* in ₹
05-Sep-16	1,193,475.00	1,193,475.00	1,150,320.00	-2,301	-7,342	45,456	89,109	0	0	81,767.00
06-Sep-16	1,191,737.50	1,191,737.50	1,150,320.00	-391	-801	41,809	96,118	0	0	95,317.00
07-Sep-16	1,220,903.12	1,220,903.12	1,150,320.00	-126	-429	70,708	217,025	0	0	216,595.00
08-Sep-16	1,223,053.12	1,223,053.12	1,150,320.00	-299	-522	73,032	169,795	0	0	169,273.00
09-Sep-16	1,159,612.50	1,159,612.50	1,150,320.00	-46,545	-42,601	55,786	87,432	-33,516	0	11,315.00
10-Sep-16	1,217,562.50	1,217,562.50	1,150,320.00	-20,811	-21,582	88,053	110,836	-11,777	0	77,478.00
11-Sep-16	1,255,421.88	1,255,421.88	1,102,560.00	0	0	126,876	172,155	0	0	172,155.00
Total	8,461,765.62	8,461,765.62	8,004,480.00	-70,473	-73,278	501,720	942,471	-45,293	0	823,900.00

* -ve (minus) implies payable by the OA Customer; + ve (plus) implies receivable by the OA customer

** CFD means Charges for Deviation and Addl_CFD means Additional Charges for Deviation

4. Technical Remarks:-

Meter_id	Meter Location:	Meter-end	Type of Meter	AMR Status at SLDC-end
APM45832	132KV Renki S/S	Consumer End	MAIN	OK

5. Letter of Credit Details:-

Avg. Weekly Payable UI/DSM for the FY15-16 (₹)	Highest Weekly Payable UI/DSM for the FY16-17 (₹)	LC to be Paid (₹)
0	11,167,234	Amount of LC as due may please be confirmed from office of the ED (Finance), CSPDCL, Raipur.

6. Billing Remarks:-

- Inconsistencies/errors observed if any, should be informed to this office within 5 days from the date of issue of the bill.
- The bill amount of DSM Charges is receivable to you from CSPDCL, which is to be settled by the O/o ED (Finance), CSPDCL, Raipur.
- The Deviation Pool A/C no. is changed and shall be maintained by CSPDCL, so there is need to make changes in LC, therefore please contact with the officials of the ED (Finance), CSPDCL at 0771-2574340. Since all the matters related to commercial settlement of DSM Charges and Letter of Credit (LC) related matters shall be taken care by CSPDCL w.e.f. 1st Nov. 2014.
New A/C details are as under :-
 (i) Name of Account - "CSPDCL DEVIATION POOL ACCOUNT"
 (ii) Name of Bank and Branch - Union Bank of India, Lilli Chowk Branch Raipur
 (iii) Vendor Sub-Account Number. - 619401010050442
 (iv) IFSC Code - UBIN0561941
- Please check the AMR status as per Sr no. 4 of this bill and rectify the error at the earliest, if any. Otherwise Open access permission/NOC may be denied.
- The details of above DSM charges statement is available in the CGSLDC website www.sldccg.gov.in under the link Commercial->DSM Charges of OAC.

7. Notice :-

- It is observed that you have contravened the limits on Deviation volume & consequences of crossing limits as specified in Regulation 7 of CERC Deviation Settlement Mechanism Regulations, 2014 as under :-
 (I).Number of time blocks where deviation from schedule exceeds 12% of scheduled-injection/ 150 MW when freq is 49.7 Hz & above and below 50.10 Hz = **84**
 (II).Number of time blocks where under-injection observed when freq is below 49.7 Hz = **0**
 (III).Number of time blocks where over-injection observed when freq is 50.10 Hz & above = **0**
 (IV).Number of time blocks where sign of deviation from schedule not changed after every 12 time-blocks = **481**
 Thus you are liable for imposing penalty under section 142 of Electricity Act 2003.
- Number of blocks when overscheduling observed = **0** and maximum deviation (in %) = **0.0**

Superintending Engineer (MO)
SLDC, CSPTCL, Raipur

